

Fire Service Summary Report: Study of the Effectiveness of Fire Service Vertical Ventilation and Suppression Tactics in Single Family Homes



**FIREFIGHTER SAFETY
RESEARCH INSTITUTE**



EVIDENCE YOU NEED.
EXPERIENCE YOU TRUST.



FIREFIGHTER SAFETY
RESEARCH INSTITUTE
ULfirefightersafety.com



Forward

This document is a subset of the full technical report titled, "Study of the Effectiveness of Fire Service Vertical Ventilation and Suppression Tactics in Single Family Homes," that can be downloaded at www.ULfirefightersafety.com. There is no additional information provided in this document rather it includes introductory material, a summary of the experimental setup, fire service tactical considerations and summary of the full report. Please refer to the full report for more detail and discussion of the results.

1. Introduction

There is a continued tragic loss of firefighter and civilian lives, as shown by fire statistics. One significant contributing factor is the lack of understanding of fire behavior in residential structures resulting from the use of ventilation as a firefighter practice on the fire ground. The changing dynamics of residential fires as a result of the changes in home construction materials, contents, size and geometry over the past 30 years compounds our lack of understanding of the effects of ventilation on fire behavior (Kerber S. , 2012). If used properly, ventilation improves visibility and reduces the chance of flashover or back draft. If a fire is not properly ventilated, it could result in an anticipated flashover, greatly reducing firefighter safety (Kerber S. , 2012).

This fire research project developed empirical data from full-scale house fire experiments to examine vertical ventilation, suppression techniques and the resulting fire behavior. The purpose of this study was to improve firefighter knowledge of the effects of vertical ventilation and the impact of different suppression techniques. The experimental results may be used to develop tactical considerations outlining firefighting ventilation and suppression practices to reduce firefighter death and injury. This fire research project will further work from previous DHS AFG sponsored research (EMW-2008-FP-01774), which studied the impact of horizontal ventilation through doors and windows (Kerber S. , 2010).

1.1. Background

NFPA estimates that from 2002-2011 (Karter, 2012), U.S. fire departments responded to an average of 398,000 residential fires annually. These fires caused an estimated annual average of 2,820 civilian deaths and 13,780 civilian injuries. More than 70% of the reported home fires and 84% of the fatal home fire injuries occurred in one- or two- family dwellings, with the remainder in apartments or similar properties. For the 2006-2009 period, there were an estimated annual average 35,743 firefighter fire ground injuries in the U.S. (Michael J. Karter & Molis, 2010) The rate of traumatic firefighter deaths occurring outside structures or from cardiac arrest has declined, while at the same time, firefighter deaths occurring inside structures has continued to climb over the past 30 years (Fahy, LeBlanc, & Molis, 2007). Improper ventilation tactics are believed to be a significant contributing factor to the increase in firefighter injuries and deaths.

Ventilation is frequently used as a firefighting tactic to control and fight fires. In firefighting, ventilation refers to the process of creating openings to remove smoke, heat and toxic gases from a burning structure and replacing them with fresh air. If used properly, ventilation improves visibility and reduces the chance of flashover or back draft. If a large fire is not properly ventilated, not only will it be much harder to fight, but it could also build up enough poorly

burned smoke to create a back draft or smoke explosion, or enough heat to create flashover. Poorly placed or timed ventilation may increase the fire's air supply, causing it to grow and spread rapidly. Used improperly, ventilation can cause the fire to grow in intensity and potentially endanger the lives of fire fighters who are between the fire and the ventilation opening.

While no known studies compile statistics on ventilation induced fire injuries and fatalities, the following are examples of recent ventilation induced fires that resulted in fire fighter injuries and fatalities.

- 1) 2 NIOSH fatality investigation reports, 98-FO7 (NIOSH, Commercial Structure Fire Claims the Life of One Fire Fighter—California, 1998) and F2004-14 (NIOSH, 2005) involved “offensive entry (that) was not coordinated with ventilation that was complete and effective” that resulted in multiple firefighter fatalities;
- 2) “While attempting to assess the extent of the fire in the attic, one of the firefighters operating on the roof fell through the weakened roof decking. The firefighter suffered burn injuries as a result of this fall. His SCBA and face piece were torn off by the rafters during the fall.” (National Firefighter Near Miss Reporting System, 2009)
- 3) A February 29, 2008 duplex fire resulted in 1 firefighter death and 1 resident death as a result of, among other factors, “lack of coordinated ventilation”. NIOSH report conclusion states “This contributory factor (tactical ventilation) points to the need for training on the influence of tactical operations (particularly ventilation) on fire behavior”. (NIOSH, 2008) ;
- 4) NIOSH fatality investigation report F2007-29 reports of a fire in a residential structure and states “...Horizontal and vertical ventilation was conducted and a powered positive pressure ventilation fan was utilized at the front door but little smoke was pushed out. Minutes later, heavy dark smoke pushed out of the front door.... Two victims (firefighters) died of smoke inhalation and thermal injuries.” (NIOSH, 2008);
- 5) While not a residential fire, the Charleston, SC fire on June 18, 2008 that resulted in 9 firefighter deaths reported that misuse of ventilation was one contributing factor. The recent NIOSH report on this event stated “A vent opening made between the fire fighter or victims and their path of egress could be fatal if the fire is pulled to their location or cuts off their path of egress.” (NIOSH, 2009)
- 6) A recent NIOSH publication documents the extent of the situation “Lives will continue to be lost unless fire departments make appropriate fundamental changes in fire-fighting tactics involving trusses. These fundamental changes include the following: Venting the roof using proper safety precautions.” (NIOSH, 2010)

As fire grows from the single ignited item to other objects in the room of fire origin, it may become ventilation controlled depending on how well the fire compartment (i.e., home) is sealed. At this stage both the fire growth and power (heat release rate) are limited by available ventilation. If the compartment is tightly sealed, the fire may ultimately self-extinguish. However, if ventilation is increased, either through tactical action of the firefighters or unplanned ventilation resulting from effects of the fire (e.g., failure of a window, ceiling, roof) or human

action (e.g., door opened), heat release will increase, potentially resulting in ventilation induced flashover conditions. These ventilation induced fire conditions are sometimes unexpectedly swift, providing little time for firefighters to react and respond.

Compounding the problem with ventilation is the changing dynamics of residential fires due to the changes in new contemporary home construction including new building materials, contents, size and layout. Many contemporary homes are larger than older homes built before 1980. Newer homes tend to incorporate open floor plans, with large spaces that contribute to rapid fire spread. The challenge of rapid fire spread is exacerbated by the use of modern building materials, construction practices, and contents. The rising cost of energy and developments of “green” building design have resulted in a significant change in attic design. Emerging trends, such as tempered attic spaces, have resulted in a shift from traditional cellulosic and fiberglass batting installed in the attic floor joists to spray applied foams installed to the underside of the roof deck.

Previous research developed experimental fire test data and was used to demonstrate fire behavior resulting from varied horizontal ventilation opening locations (doors and windows) in legacy residential structures compared to modern residential structures. This project advances knowledge by investigating the effect of vertical ventilation through ceiling / attic / roofs. Many positive responses were received from firefighters following the release of the previous research project’s online training program. In addition, it was requested that UL address vertical ventilation and further address suppression tactics. This study will address these requests and the lack of available data. The data will be used to provide education and guidance to the fire service in proper use of vertical ventilation as a firefighting tactic that will result in mitigation of the firefighter injury and death risk associated with improper use of ventilation.

1.2. Understanding Limitations

Every fire event that the fire service responds to is unique, as the range of fire ground variables at each fire event makes firefighting complex. In this investigation, key variables were identified and bounded to develop the data under controlled conditions. These variables included house geometry, fuel loading, fire department arrival time, tactical choices, hose stream flow rates, and ventilation locations. By bounding these variables and controlling the test conditions during firefighting operations, the impact of vertical ventilation operations and fire suppression tactics on fire dynamics and conditions in two types of single family homes was examined. The results enable the establishment of a scientific basis that may be used for other types of structures that are not single family homes, different sized rooms, different fuel loads, different interior geometries, different timing of operations, etc.

The purpose of this study is not to establish if vertical ventilation or exterior suppression is more effective. The purpose is to increase the fire service’s knowledge of the impact of these tactics under specific conditions. Since all fire ground circumstances cannot be analyzed, it is anticipated that the data developed and this analysis enable firefighters to complement their previous observations and experiences.

This study does not consider the safety of physically conducting vertical ventilation operations. As shown in previous UL studies, wood roof systems burn and collapse which makes operating on top of a roof on fire a dangerous operation that should only be done with a risk/benefit

analysis by the firefighters. Many firefighters have lost their lives due to collapse of a roof system while performing vertical ventilation. The information from this report can be incorporated into the size-up considerations of the fire service so that vertical ventilation is used to the best benefit possible when it is determined to be an appropriate tactic.

The fires in this study, where vertical ventilation was used, were content fires and represented a fire event within the living space of the home, and not a structure fire with fire extension into the attic space. These experiments were also meant to simulate initial fire service operations by an engine company or engine and truck company arriving together in short order with approximately national average response times. Additional experiments have been conducted to begin to examine vertically ventilating an attic fire and will be documented separately.

2. Project Technical Panel

A technical panel of fire service and research experts was assembled based on their previous experience with research studies, ventilation practices, scientific knowledge, practical knowledge, professional affiliations, and dissemination to the fire service. They provided valuable input into all aspects of this project, such as experimental design and identification of tactical considerations. The panel made this project relevant and possible for the scientific results to be applicable to firefighters and officers of all levels. The panel consisted of:

- Josh Blum, Deputy Chief, Loveland – Symmes (OH) Fire Department
- John Ceriello, Lieutenant, Fire Department of New York
- James Dalton, Coordinator of Research, Chicago Fire Department
- Ed Hadfield, Division Chief, City of Coronado (CA) Fire Department
- Todd Harms, Assistant Chief, Phoenix Fire Department
- Ed Hartin, Chief, Central Whidbey Island Fire Rescue Department
- George Healy, Battalion Chief, Fire Department of New York
- Otto Huber, Fire Chief, Loveland – Symmes (OH) Fire Department
- Dan Madrzykowski, Fire Protection Engineer, National Institute of Standards and Technology
- Mark Nolan, Fire Chief, City of Northbrook (IL)
- David Rhodes, Battalion Chief, Atlanta Fire Department
- David Rickert, Firefighter, Milwaukee Fire Department
- Andy Rick, Firefighter, Lake Forest (IL) Fire Department
- Pete Van Dorpe, Chief of Training, Chicago Fire Department
- Sean DeCrane, Battalion Chief, Cleveland Fire Department
- Bobby Halton, Editor, Fire Engineering Magazine
- Harvey Eisner, Editor, Firehouse Magazine
- Tim Sendelbach, Editor, Fire Rescue Magazine

3. Full-Scale House Experiments

The project technical panel designed a series of 17 experiments to examine several scenarios that were identified as gaps in current fire service knowledge of fire dynamics, ventilation and suppression. These gaps include:

- Impact of door control
- Impact of vertical ventilation hole size
- Impact of vertical ventilation hole location
- Impact of different flow paths between fire location and ventilation location
- Impact of modern and legacy fuel loads in a structure
- Impact of exterior suppression with various flow path configurations

To examine these knowledge gaps in vertical ventilation practices, suppression practices as well as the impact of changes in modern house geometries and contents, two houses were constructed in the large fire facility of Underwriters Laboratories in Northbrook, IL. Seventeen experiments were conducted, varying the ventilation locations, fire ignition location and the timing of ventilation openings (Table 3.1 and Table 3.2).

Ventilation scenarios included ventilating the front door and a window near the seat of the fire to link these experiments to previous horizontal ventilation experiments, opening the front door and a ventilation hole above the seat of the fire and remote from the seat of the fire, and opening the front door and opening a large hole above the fire. Suppression scenarios included igniting a fire in the kitchen, opening the front door and flowing water into the kitchen with the dining room window closed and open. Another suppression experiment included igniting a fire in the living room, creating a flow path from the front door through Bedroom 1 and flowing water through the front door. A final scenario in the 1-story house examined opening the front door and living room window while the living room was furnished with legacy fuel. Details of the structures, instrumentation, fuel load and results follow in this section.

Table 3.1: One-Story Experimental Details

Experiment #	Structure	Location of Ignition	Ventilation Parameters
1	1-Story	Living Room	Front Door + Living Room Window
3	1-Story	Living Room	Front Door Partially Open + Roof (4' by 4')
5	1-Story	Living Room	Front Door + Roof (4' by 4')
7	1-Story	Living Room	Front Door + Roof (4' by 8')
9	1-Story	Bedroom 1	Front Door + Roof (4' by 4') + Bedroom 1 Window
11	1-Story	Bedroom 1	Bedroom 1 Window + Front Door + Roof (4' by 4')
13	1-Story	Kitchen	Front Door + Dining Room Window
15	1-Story	Living Room	Living Room + Bedroom 1 Window
17	1-Story	Living Room	Front Door + Living Room Window

Table 3.2: Two-story Experimental Details

Experiment #	Structure	Location of Ignition	Ventilation Parameters
2	2-Story	Family Room	Front Door + Family Room Window
4	2-Story	Family Room	Front Door Partially Open + Roof (4' by 4')
6	2-Story	Family Room	Front Door + Roof (4' by 4')
8	2-Story	Family Room	Front Door + Roof (4' by 8')
10	2-Story	Bedroom 3	Front Door + Roof (4' by 4') + Bedroom 3 Window
12	2-Story	Family Room	Family Room Window + Front Door + Roof (4' by 4')
14	2-Story	Bedroom 3	Bedroom 3 Window + Front Door + Roof (4' by 4')
16	2-Story	Kitchen	Family Room Window (nearer Kitchen) + Bedroom 3 Window

3.1. One-Story Structure

Seven of the 17 experiments took place in the one-story house. The house was designed by a residential architectural company to be representative of a home constructed in the mid-twentieth century with walls and doorways separating all of the rooms and 8 ft. ceilings. The experiments aim to examine the fire dynamics in a structure of this type and to further understand the impact of different types of ventilation on tenability throughout the structure.

The one-story house had an area of 1200 ft², with 3 bedrooms, 1 bathroom and 8 total rooms (Figure 3.1 through Figure 3.4). The home was a wood frame, type 5 structure lined with two layers of gypsum board (Base layer 5/8 in, Surface layer 1/2 in.) The roof was metal truss construction and was lined with 1/2 in. cement board to provide a volume to represent an attic void. A roof ventilation system was created above the Living Room to allow for remote roof ventilation. Hinged openings were able to be opened simulating a roof cut being “pulled” and a section of ceiling was able to be removed simulating the ceiling being “pushed” through from above. The front and rear of the structure were covered with cement board to limit exterior fire spread. Figure 3.5 is a 3D rendering of the house with the roof cut away to show the interior layout with furniture and floor coverings. The tan floor shows the carpet placement and the grey show the cement floor or simulated tile locations.



Figure 3.1: One-Story Front



Figure 3.3: One-Story Rear



Figure 3.2: One-Story Roof




Figure 3.4: One-Story House Floor Plan




Figure 3.5: 3D Rendering of the One-Story House from the Front

3.2. Two-Story Structure

The two-story house had an area of 3200 ft², with 4 bedrooms, 2.5 bathrooms house and 12 total rooms (Figure 3.6 through Figure 3.12). This home was also a wood frame, type 5 structure lined with two layers of gypsum board (Base layer 5/8 in, Surface layer 1/2 in.) The roof was engineered I-joist construction but not sheathed because the fires were content fires only and not structure fires. A roof ventilation system was created above the Family Room to allow for remote roof ventilation. Hinged sections of roof could be opened to simulate a roof cut being completed. This section did not have an interior ceiling to be “pushed” because this section of the roof above the great room was simulated to be a cathedral style ceiling, having no void below the roof. The front and rear of the structure were covered with cement board to limit exterior fire spread.



Figure 3.6: Two-Story Front



Figure 3.7: Two-Story Rear



Figure 3.8: Two-Story Roof




Figure 3.9. 3D Rendering of the 2-Story House from the Front




Figure 3.10. 3D Rendering of the 2-Story House from the Back




Figure 3.11. Two-Story House First Floor Plan




Figure 3.12. Two-Story House Second Floor Plan

3.3. Experimental Methodology

All of the experiments started with the exterior doors and windows closed, the roof vents closed, and all of the interior doors in the same locations (i.e., either open or closed). The fire was ignited using a remote ignition device comprising of five stick matches (Figure 3.13) and electrically energized with a fine wire to heat the match heads, and create a small flaming ignition source. The ignition locations are shown in Figure 3.14 through Figure 3.16.



Figure 3.13: Ignition Matches



Figure 3.14: One-Story Living Room Ignition Location



Figure 3.15: Two-Story Family Room Ignition Location



Figure 3.16: Bedroom Ignition Location

The flaming fire was allowed to grow until ventilation operations were performed by making openings. The one story house was ventilated 8 minutes after ignition. This was determined based on two factors: time to achieve ventilation-limited conditions in the house and potential response and intervention times of the fire service. The ventilation time for the two story house was 10 minutes for the same reasons as the one story house and the additional time enabled ventilation-limited conditions. The same fuel package was used in the two-story family room with a 17 ft. ceiling and open floor plan as was used in the one-story house with an 8 ft ceiling and compartmented floor plan therefore the two-story house required a longer time to become ventilation-limited.

Ventilation scenarios included ventilating the front door and a window near the seat of the fire to link these experiments to previous horizontal ventilation experiments, opening the front door and a ventilation hole above the seat of the fire and remote from the seat of the fire, and opening the

front door and opening a large hole above the fire. Suppression scenarios included igniting a fire in the kitchen, opening the front door and flowing water into the kitchen with the dining room window closed and open. Another suppression experiment included igniting a fire in the living room, creating a flow path from the front door through Bedroom 1 and flowing water through the front door. A final scenario in the 1-story house examined opening the front door and living room window while the living room was furnished with legacy fuel.

In most cases in the field vertical ventilation and horizontal ventilation are performed at different time scales. There is an obvious difference between ventilating a glass window with a tool from the ground versus climbing to the roof and creating a ventilation hole through the roof membrane. Therefore, the timing of the vertical ventilation openings was done based on interior conditions and not a certain time. The most frequent criteria chosen was a 3 ft. temperature of 400 °F in the area that a firefighting crew could be operating. This approach may be justified by the fact that a crew operating in that area could request that vertical ventilation is completed to improve the conditions in the area in which they were operating. The timing of these openings will be explained and examined for each experiment in the discussion section of the report.

After ventilation, the fire was allowed to grow until flashover or perceived maximum burning rate occurred. This was based on the temperatures, observation of exterior conditions, and monitoring of the internal video. Once the fire maintained a peak for a period of time with respect given to wall lining integrity (prior to transition from a content fire to a structure fire), a hose stream was flowed in through an external opening.

Incorporated into every experiment was a stream of water directed into a ventilation opening for approximately 15 seconds. The hose line used was a 1 ¾ inch with a combination nozzle with approximately 100 psi nozzle pressure, creating a flow of 100 gpm. Two types of flow patterns were used during the experiments, straight stream and fog. During straight stream application the nozzle was adjusted to a straight stream pattern and directed into the structure with the guidance of putting water on what was burning, so the nozzle was not held stationary. During the fog stream application the nozzle was adjusted to create an approximate 30 degree fog pattern and also directed into the structure with the intent to extinguish the visible fire while not holding the nozzle stationary.

The flow rate of the nozzle was 100 gpm resulting in approximately 25 gallons of water delivered through the opening into the house during the 15 second flow. The purpose of this flow was not to enable firefighters to move into the structure and extinguish the fire but to suppress as much fire as possible and to observe the conditions in the surrounding rooms. This has an impact on the tactical considerations as discussed later in the report. This would allow the potential fire attack crew to slow the fire down, or soften the target, prior to making entry, therefore make entry into a safer environment. The experiment was terminated at least one minute after the hose stream, and suppression was completed by the firefighting crew.

4. Tactical Considerations

In this section, the results of all the experiments are discussed to develop relationship to tactics on the fire ground as it may impact the safety of the fire service. The topics examined in this section were identified by the project's technical panel.

The application of the findings discussed in this section to the fire scene depend upon many factors such as (i) building structure; (ii) capabilities and resources available to the first responding fire department; and (iii) availability of mutual aid. In addition, the tactical considerations provided should be viewed as concepts for the responding fire service personnel to consider at the fire scene.

4.1. Modern versus Legacy Fire Development

As more and more home furnishings are made of synthetic materials, the heat release rate generated by furniture has increased significantly. This change speeds up the stages of fire development, creating an increased potential for ventilation-limited fire conditions prior to fire department arrival.

The fire service's workplace has changed and one of several significant factors is home furnishings. As home furnishings have evolved over decades to be made of synthetic materials, the heat release rates generated by home furnishings have increased significantly. This change speeds up the stages of fire development creating an increased potential for ventilation-limited fire conditions prior to fire department arrival. Earlier ventilation-limited conditions make the ventilation tactics of the fire service of utmost importance. Figure 4.1 details many differences of how fires develop today versus decades ago. Peak temperatures prior to becoming ventilation-limited are very different: 1100 °F in the modern fire, compared to 450 °F in the legacy fire. The minimum oxygen concentration prior to fire service ventilation was 5% in the modern fire, compared to 18% in the legacy fire. Most importantly, the time between ventilation and flashover are 2 minutes for the modern fire and over 8 minutes in the legacy fire. The legacy fire could be described as forgiving as it pertains to ventilation. Poorly timed ventilation or an uncoordinated attack can be made up for prior to flashover because there is 8 minutes to adapt. The time to recover in the modern fire was only 2 minutes, or 25% of the legacy time. This supports the adage, "You are not fighting your grandfather's fire anymore."




Figure 4.1: Modern vs. Legacy Temperatures and Oxygen Concentration Comparison

4.2. Control the Access Door

While opening a door is a necessity for gaining access, if you limit the amount of air entering, you limit the fire's ability to grow. The experiments in the previous UL horizontal ventilation study demonstrated that opening the front door needs to be thought of as ventilation, as well as making an access point. This necessary tactic also needs to be coordinated with the rest of the operations on the fire ground. A simple action of pulling the front door closed after forcing entry will limit the air to the fire and slow the potential rapid fire progression until access is ready to be made as part of the coordinated attack. The same results were observed in these experiments, and two of the experiments were designed to take it a step further.

One experiment in each house simulated door control. First, the front door was opened fully to allow simulated crew access and then the door was controlled by pulling it closed to the width of a hoseline traveling straight through the doorway (Figure 4.2). This simulated having a control man at the door, feeding hose and holding the door as closed as possible to not impede the advancement of the line. The fire room temperatures at firefighter crawling height from both houses are shown in Figure 4.3 and Figure 4.4. These graphs show that controlling the door keeps temperatures lower than completely opening the door. Temperatures are shown from time of door opening until just before the roof vent was opened so the only effect on temperature was from the front door.

The fire dynamics of door control are fairly simple. If you have a ventilation-limited fire and you limit the air, then you limit the heat able to be released. While this does not completely cut

off the oxygen supply, it slows it, which slows fire growth. The more the door is closed, the less the fire can grow. The less the fire grows, the less water required to bring it under control and extinguish it. Doors are also the most efficient air inlet because they go all the way to the ground, as opposed to a window. The air gets entrained low in the doorway, while products of combustion can flow out the top of the doorway, creating a complete flow path through the same opening.

Tactically, there are several considerations for door control. Most importantly, it is a temporary action. The door should be controlled until water is applied to the fire. Once water goes on the fire and the attack crew has the upper hand, meaning more energy is being absorbed by the water than is being created by the fire, the door can be opened. At that point, it is no longer a ventilation-limited fire, so all ventilation will allow more hot gases and smoke out than are being created by the fire. If you are able to apply water to the fire quickly, then this tactic is not needed. Door control does not only have to be done with the front door or with a hoseline. During a search, interior doors can be controlled as crews are trying to find and control the fire or find victims. Any door that has the potential to feed air to the fire should be controlled until water is on the fire or the fire is contained to a known room. If there is concern that a door will lock and trap a crew, a tool can be placed in the doorway to prevent the door from closing and locking.

If there are concerns that an access door will not be able to be reopened after the crew enters, then it should not be controlled, but the potential impact of the added air should be factored in to the operation. One of the most dangerous places for a firefighter to be is between where the fire is and where it wants to go. If the door behind you is the only outlet, then the fire wants to go over or through you to the door.



Figure 4.2: Door Control with a 1 3/4 inch Hoseline




Figure 4.3: One-Story Living Room Temperatures after Front Door Open and Before Roof Open




Figure 4.4: Two-Story Family Room Temperatures after Front Door Open and Before Roof Open

4.3. Coordinated Attack Includes Vertical Ventilation

“Taking the lid off” does not guarantee positive results. Most firefighters will tell you that the roof needs to be opened to accomplish two main things: 1) quickly slow down the horizontal fire spread of fire by channeling it where it wants to go, upward; and 2) improve the atmosphere inside the structure so other operations can take place in a safer environment. Most fire training publications describe the benefits of vertical ventilation in this way. There is a significant caveat to this description, and it has to do with the air allowed in to the compartment that is being vertically ventilated.

Vertical ventilation is the most efficient type of natural ventilation. It allows the hottest gases to exit the structure quickly. However, it also allows the most air to be entrained into the structure through a horizontal entry vent, such as a door. If the fire is ventilation-limited, the air entrained can produce an increased burning rate than can be exhausted out of the vertical ventilation hole. When this occurs, conditions can deteriorate within the structure very quickly, which is not the intent of the ventilation operation.

The answer is coordination of vertical ventilation with fire attack, just like one would expect with horizontal ventilation. To make sure the fire does not get larger and that ventilation works as intended, take the fire from ventilation-limited (where it needs air to grow) to fuel limited by applying water. As soon as the water has the upper hand and more energy is being absorbed by the water than is being created by the fire, ventilation will begin to work as intended. With vertical ventilation, this will happen faster than with horizontal ventilation, assuming similar vent sizes.

Opening the roof of any structure is not a fast operation, when compared to ventilating a window. Even if there are skylights, it takes additional time to get to the roof. Because of the time this tactic takes, it is commonly done after a charged hoseline is in place and having an impact, or has already suppressed the fire. That said, there is the potential that the roof vent could be opened before the engine company has a charged hoseline in position to begin fire control. In such cases, the roof could be cut, but pulling or louvering the cut could be held until the incident commander or interior crews indicate that roof ventilation is needed. Once coordinated, the result has a much better chance of having a safe and effective outcome.

Take Experiment 5 in the one-story house as an example. There is a narrow window of opportunity before temperatures in the entire house rise because of added oxygen (Figure 4.5, Figure 4.6 and Figure 4.7). Opening the front door started the process of providing oxygen to the ventilation-limited fire. The fire would have transitioned to flashover without the roof vent, but creating an opening above the fire speeds the process. Many would think that opening that hole would slow the process down by allowing hot gases out, but the air allowed in generates more heat and smoke than can escape through the 4 ft. by 4 ft. hole.



Figure 4.5: 5 seconds after roof vent



Figure 4.6: 60 seconds after roof vent




Figure 4.7: 5 ft. temperatures in the one-story house showing coordination window

4.4. How big of a hole?

A 4 ft. by 8 ft. hole over a ventilation-limited fire does not get rid of more smoke and hot gases than are created by the flow of oxygen through the front door. Fire training often refers to a 4 ft. by 4 ft. hole as the vertical ventilation hole size required for a single family house, but there is no reason provided for this estimation. Alternative ventilation hole size guidance found in fire service literature recommends 10% of the container size beneath the hole. The one-story house has a living room that is approximately 230 ft², which equates to a 4 ft. by 6 ft. hole. The two

story house has a family room that is approximately the same size but it also has an open floor plan, so there is no defined container size.

For each structure, two ventilation holes were created - one 4 ft. by 4 ft. and one 4 ft. by 8 ft. The holes were created over the living room fire in the one story and over the family room fire in the two-story. The front door was open in each house simulating crew entry, and assuming the fire department would not wait for vertical ventilation to be the only task completed during a fire attack (Figure 4.8 through Figure 4.11). These graphs show the conditions after ventilation in each case and a graph of the temperatures in every room from the time of vertical ventilation until water was applied. The only impact on these temperatures is the ventilation taking place, and the graphs show that ventilation alone did not localize fire growth or reduce temperatures as compared to not performing vertical ventilation.

The data from these experiments show that a 4 ft. by 8 ft. hole above the fire in each of the houses alone did not improve conditions or make ventilation-limited fire conditions into fuel-limited conditions. When water was applied to the fire to reduce the heat release, the fire transitioned to a fuel-controlled fire. At that point, the larger the hole, the better conditions became for any potential victims or firefighters operating inside the structure.



Figure 4.8: One-Story, 4 ft. by 4 ft.






Figure 4.9: One-Story, 4 ft. by 8 ft.




Figure 4.10: Two-Story, 4 ft. by 4 ft.





Figure 4.11: Two-Story, 4 ft. by 8 ft.



4.5. Where do you vent?

Ventilating over the fire is the best choice if your fire attack is coordinated. The coordinated attack tactical consideration established that a ventilation-limited fire would increase in size if it receives air. Additionally, the closer the source of the air to the seat of the fire, the quicker it will increase in size (the heat release rate will increase and temperatures will increase).

Placement of vertical ventilation can be a complex situation, especially if you do not know where the fire is in the house. Optimally, you plan your vertical ventilation based on the room geometry, door locations, air inlet location, and subsequent flow paths. If you ventilate in coordination with fire attack, the hose stream is removing more energy than is being created, so it does not matter where you ventilate. But the closer it is to the seat of the fire, the more efficient the vent will be in removing heat and smoke, which will improve conditions for the remainder of the operations taking place on the fire ground. If you vertically ventilate and fire attack is delayed, then ventilating in general is bad, and vertically ventilating in close proximity to the seat of the fire will result in the worst conditions the fastest. With today's fuel loads and heat release rates, there is a good chance that the fire will generate enough energy quickly enough to overwhelm any vent that is created. Simply put, the fire is producing more than can be let out, so conditions get worse in the absence of water application.

Ventilating remote from the fire can be effective under some circumstances. If the fire is in a room that is connected to the rest of the house by a doorway, ventilating the roof outside of that room could allow smoke to clear from the rest of the house. However, while visibility may improve in the flow path leading from the air inlet to the fire room, the fire will increase in size as the air is entrained. The doorway becomes the limiting factor in keeping the fire contained. Once fuel outside of that doorway ignites, such as a bedroom fire extending to living room furniture, the heat release rate can increase quickly and overcome the temporary benefit of the remote vertical ventilation hole. This is an example of a situation where the vertical vent can provide a temporary visibility benefit, but the fire and temperatures in the area of the fire are continuing to increase.

4.6. Stages of Fire Growth and Flow Paths

The stage that the fire is in, ventilation- or fuel-limited, the distance from the inlet (door or window) air to the fire, the distance from the fire to the outlet (door, window, roof vent), the shape of the inlet and outlet and the type and shape of items (furniture or walls), or openings (interior doors) in the flow paths, all play key roles in how quickly a fire will respond to oxygen and ultimately firefighter safety.

Flow paths can be defined as the movement of heat and smoke from the higher air pressure within the fire area to all other lower air pressure areas both inside and outside of a fire building. As the heated fire gases are moving towards the low pressure areas, the energy of the fire is entraining oxygen towards the fire, as the fire is rapidly consuming the available oxygen in the area. Based on varying building design and the available ventilation openings (doors, windows, etc.), there may be several flow paths within a structure. Operations conducted in the flow path can place firefighters at significant risk due to the increased flow of fire, heat, and smoke toward their position.

The following series of images and text shows a one-story house fire that begins in the living room.

Figure 4.12 shows the heat release rate of the fire as the fire progresses. The following series of images illustrates the relative temperatures in the house and the flow path(s) indicated with blue and red arrows. After an object ignites in the living room, the **growth stage** of the fire begins. During this stage, the fire is **fuel-limited/controlled** (not because fuel is absent but rather because it is not involved in the fire yet) and air feeds the fire from all directions and smoke and hot gases are spread along the ceiling to all of the open rooms in the house.

As the fire grows in the compartment, the smoke layer reaches the location where burning is taking place. This is still the **growth stage** but the fire becomes **ventilation-limited/controlled**. The fire is still growing but this growth slows down because the fire does not have all the air it needs to burn freely as if it were not in a compartment. The oxygen concentration begins at 21%, but, as the oxygen is consumed, the fresh air entrained to the fire begins to mix with smoke, lowering the oxygen concentration and slowing fire growth. Also during this stage, the fire has most likely spread beyond the first object ignited and can be considered a compartment fire or room fire. Once the oxygen concentration drops below approximately 16%, the fire begins its **initial decay stage**. The oxygen level at which this occurs varies, but depends mainly on the temperature in the room. Higher temperatures before the oxygen concentration decreases will support longer fire growth before the decay stage. As the fire decays, temperatures in the fire room remain high, but temperatures throughout the rest of the house decrease as heat release rate decreases. During this stage there is no significant flow path. The fire is trying to entrain air from any void or crack in the house, which may look like pulsing smoke from the outside.

A decaying fire must entrain more oxygen, or it will self-extinguish. Ventilation, which provides the fire the access to oxygen that it needs, can be caused a number of ways, by the fire failing a window or glass door, by a neighbor or a police officer trying to help, or by the fire department venting a window or forcing open a door. Once an opening is made, a **second growth stage** begins. The speed at which the fire responds and the speed at which the heat release rate increases depends on the extent to which the fire decayed and the distance between the air supply and the burning room. Awareness of the flow path during this stage is critical, because firefighters will interact with the ventilation-limited fire at this time. They have the potential to be in the flow path when the fire changes rapidly. In this scenario, the front door enters right into the fire room. The resulting flow path consists of fresh air flowing in through the bottom half of the front door, or low pressure, and hot gases and smoke flowing out through the top of the door under a higher pressure. Controlling the front door or applying water is the only ways to slow the second growth stage of the fire.

During the second growth stage, if the door is not controlled or water is not applied, the fire will transition to flashover. **Flashover** is a momentary event that occurs during the second growth stage. After flashover the fire grows to the point where there is more burning (heat release rate) than can be supported by the air coming in through the front door. Fuel rich smoke and hot gases flow out of the front door and meet the oxygen outside of the house and burn outside the house. This is what the fire service would refer to as “fire showing.” At this stage, the fire is ventilation-limited and temperatures in the house will remain high. The fire is not vented, but it is venting, and if no additional windows fail, doors are opened, or holes are cut in the roof, the fire enters the **fully developed stage**. The fire will burn at the same heat release rate unless

additional oxygen is made available to the fire, or if fuel is consumed to the point the fire pulls back into the house and becomes fuel limited or if water is applied to the fire returning it to a fuel limited fire.

In this scenario a vertical ventilation hole is made into the fire room. This transitions the fire into a third **growth stage**. The heat release rate increases as additional smoke and hot gases are ventilated out of the roof, which allows more oxygen to be entrained into the front door. The flow path inward increases in size and speed while the outward flow path splits. The majority of the outflow is through the roof while some remains out of the front door. With fuel remaining, there is now fire out of the roof and front door and the fire is still ventilation-limited. Since it is ventilation-limited, it enters a **second fully developed stage**. The fire will remain at this stage until additional oxygen is made available to the fire (opening a window, opening a door, or making a larger roof hole); fuel is consumed to the point that the fire pulls back into the house and becomes fuel limited; or water is applied to the fire, returning it to a fuel limited fire.

In this scenario, **suppression** is commenced. This marks the start of the **decay stage**. The heat release rate is reduced, controlling the fire and returning it to a **fuel-limited fire**. During this stage more hot gases and smoke are being ventilated than are being created, so the house temperatures will cool and the visibility will improve, allowing for searches, extinguishment, salvage, overhaul, etc.

Experiment 5 followed a similar timeline to this example. Figure 4.13 shows an overlay of stages of fire growth over the actual temperatures in the house during the experiment. The only difference is the timing between the front door being opened and the roof vent being opened. In the example, flashover occurred prior to roof ventilation, and in the experiment, the roof was opened sooner, and flashover occurred after roof ventilation. This figure provides an approximation of what non-fire room temperatures would be in the example as the ventilation occurs and the stages of fire development take place.






Figure 4.12: Fire growth curve for this fire example




Growth Stage: Ventilation-limited Fire. Room on fire, oxygen is decreasing

Flow Path – Oxygen flows to fire room from all directions (BLUE Arrows) and hot gases flow away from fire at all levels (RED Arrows).



Initial decay stage: Ventilation-limited Fire. Room on fire, oxygen is running out and temperatures are dropping


Flow Path – Oxygen flows to fire room through cracks or leakage from all directions and hot gases also attempt to push through cracks, There can be some pulsing of smoke visualized.



Ventilation Takes Place: Door is Opened,


Growth Stage 2: Ventilation-limited Fire. Room on fire, oxygen is pulled in and temperatures are increasing

Flow Path – Oxygen flows to fire room through bottom of open front door (BLUE Arrow) and hot gases push out of the top of the doorway (RED Arrow)




Flashover: Ventilation-limited Fire. Flames extend out of doorway, inside house is too fuel rich to burn

Flow Path – Oxygen meets fuel at doorway (BLUE Arrow) and flames push out of the top of the doorway (RED Arrow)



Fully Developed Stage: Ventilation-limited Fire. Flames extend out of doorway, inside house is too fuel rich to burn but continues to increase in temperature


Flow Path – Oxygen meets fuel at doorway (BLUE Arrow) and flames push out of the top of the doorway (RED Arrow)



Additional Ventilation is made, Roof Ventilation.


Growth Stage 3: Ventilation-limited Fire. Flames extend out of doorway and roof vent, inside house is too fuel rich to burn but continues to increase in temperature

Flow Path – Oxygen meets fuel at doorway (BLUE Arrow) and flames push out of the top of the doorway and roof (RED Arrows)




Fully Developed Stage 2:
Ventilation-limited Fire.
Flames continue to extend out
of doorway and roof vent,
inside house is too fuel rich to
burn but temperatures remain
high

Flow Path – Oxygen meets
fuel at doorway (BLUE
Arrow) and flames push out of
the top of the doorway and
roof (RED Arrows)



Water Application: Fuel
Limited Fire. Temperatures
are cooled.

Flow Path – Oxygen enters
front door (BLUE Arrow) and
hot gases exit mainly through
roof and through the front
door, cooling temperatures in
the entire house (RED Arrows)






Figure 4.13: Experiment 5 Stages of Fire Development

In the one-story experiments we opened the front door to the house and ventilated over the living room fire or we opened the front door and ventilated remotely from the bedroom fire (over the living room). The location of the fresh air was the same but the air had to travel different paths to grow the fire and the hot gases had to travel different paths to exit the structure. These fire dynamics are key to understanding how the fire will react to ventilation. Opening the roof over the fire (the pre-heated room full of unburned fuel) and allowing air in right to the base of what is burning is the most efficient way to allow the fire to increase in magnitude (heat release rate) (Figure 4.14).

Opening the front door and the roof outside of the fire room and entraining the air from outside the room places a doorway in the flow path, which significantly impact the fire dynamics (Figure 4.15). Once the vents are opened, the neutral plane lifts, allowing hot gases to exit the top of the fire room doorway and for fresh air to be entrained into the bottom of the doorway. Since the hot gases need to flow from the ceiling of the fire room (the high pressure area) and downward to go through the door, this slows down the flow as the gases make their way to the low pressure, which is the roof vent and front door. The low pressure side of the flow path is from the front door to the bottom portion of the fire room door.

While the fresh air travels this path, it mixes with smoke and unburned gases, which make it less than 21% oxygen and therefore less efficient to grow the fire. With the doorway as a choke point, the fire grows slower when it is remote from the vent points. Once the fire entrains enough

air, however, it will transition to flashover, and flames and hot gases will exit the room and spread toward the vents. If other fuels are in this path, they will ignite and increase the HRR rapidly because they are in a preheated environment with additional unburned fuel from the initial fire room (Figure 4.16). This fire will then spread until it becomes ventilation-limited, with the new flow path directly into the living room. There are now 2 fire rooms, but the original fire room (bedroom) will have burning decrease and temperatures reduce because oxygen is being consumed by the living room fire, so oxygen never makes it back to the bedroom (Figure 4.17).

Figure 4.18 shows the flow paths after the front bedroom window was ventilated. The front bedroom (original fire room) was full of unburned fuel and was heated due to the combustion in the room. Once the window was opened, air was able to mix with the fuel and heat to ignite and burn. The bedroom would transition to flashover and become fully developed with fire coming from the front door, bedroom window and roof vent.

The home continues to burn in the fully developed stage until the rear bedroom window was ventilated. This creates a flow path through the rear bedroom and into the hallway, supplying air to the high heat condition in the hallway. The open window allows hot gases to flow to the low pressure and out through the top of the window (Figure 4.19). As these gases flow out of the bedroom, they heat this room, and once an object in the room ignites it increases the HRR rapidly. Figure 4.20 shows the flow paths after the rear bedroom transitions to flashover.

The fire is fully developed, and the flow paths exist at the ventilation openings because the interior of the house is ventilation-limited and the air to burn is on the outside of the home. The dining room and kitchen area are elevated in temperature, but are not burning. This is due to the lack of oxygen in the house. If the windows to those rooms were ventilated or fail due to the heat, then they would transition to flashover as well. This example shows a house burning with only ventilation added. If water was applied to this fire at any point, the heat release rate and temperatures would decrease and the ventilation would begin to assist in letting more combustion products out than are being created by the fire. In other words, the fire would transition from a ventilation-limited fire to a fuel-limited fire. Limiting flow paths until water is ready to be applied is important to limiting heat release and temperatures in the house.



Figure 4.14: Flow path directly into and out of the fire room




Figure 4.15: Flow path through another room to the seat of the fire




Figure 4.16: Flow path as furnishings are ignited in the living room




Figure 4.17: Flow path after the living room reaches flashover




Figure 4.18: Flow paths after front bedroom window is opened



Figure 4.19: Flow paths after rear bedroom is opened



Figure 4.20: Flow paths as fire becomes fully developed

4.7. Timing is vital

Firefighters performing effective ventilation are thinking about timing. It is not possible to make statements about the effectiveness of ventilation unless you include timing. In previous tactical considerations, we examined coordination, where to vent, and flow paths. All of these discussions hinge on proper timing. Every firefighter that has performed ventilation on a fire ground has seen the outcome of their actions, but do they know why? In some cases, the conditions inside may have been improved and in others, the fire may have transitioned to flashover. It is essential that every firefighter know why the fire responded the way it did by having an understanding of fire dynamics. Otherwise, that experience may be wasted or be wrong and misapplied in the future.

Venting does not always equal cooling, but well-timed and placed ventilation equals improved conditions. These improved conditions are cooling, increased visibility, useful flow paths opposite a hose line to release steam expansion, and other benefits. That same ventilation action 30 seconds earlier or later could have a dramatically different outcome. This is especially true for vertical ventilation. Vertical ventilation is the most efficient, and therefore causes the most rapid changes. A good example of this is when a content fire is vertically ventilated into a wood framed attic space. When the vent is opened and the ceiling is pushed, the fire will extend into the attic space. Since the attic is designed to be ventilated even before the vent hole is cut, there is often plenty of air and fuel to burn. If water is not going to be applied to the interior fire and followed with overhaul in the area of the vertical vent hole, then the roof could burn out of control.

As we discuss timing there are several useful considerations:

- The fire does not react to additional oxygen instantaneously. A ventilation action may appear to be positive at first, as air is entrained into the ventilation-limited fire; however, 2 minutes later, conditions could become deadly without water application.
- The higher the interior temperatures, the faster the fire reacts. If fire is showing on arrival, the interior temperatures are higher than if the house is closed. This means that additional ventilation openings are going to create more burning in a shorter period of time.
- The closer the air is to the fire, the faster the fire reacts. Venting the fire room will increase burning faster, but it will also let the hot gases out faster after water is applied.
- The higher the ventilation, the faster the fire reacts. Faster and more efficient ventilation means faster air entrainment, which means more burning and higher temperatures. It also means better ventilation after water is applied.
- The more air, the faster the fire reacts. Also, the more exhaust, the more air that can be entrained into the fire. A bigger ventilation hole in the roof means that more air will be entrained into the fire. If the fire is fuel limited, this is good, but if the fire is ventilation-limited, this could be bad.

4.8. Reading Smoke

Observing smoke conditions is a very important component of size-up. Don't get complacent if there is nothing showing on arrival. Figure 4.21 shows conditions on side alpha during an experiment in the one-story house. The top two pictures are 10 seconds prior to the interior temperatures reaching their peak, the smoke coming out of the cracks of the structure transitions from black and under pressure to grey with less pressure. Ten seconds later, there is no visible smoke showing at all. The fire has run out of oxygen and is decaying. The picture on the bottom right shows the conditions once the front door was opened.

Figure 4.22 shows the pressures decreasing rapidly to negative values as smoke flow stops and the oxygen concentration falling rapidly as the fire reaches its peak temperature and begins to decay. Comparing the temperature data with the pressure data shows that the pressure in the house goes negative while the living room is still 800 °F. No or little smoke showing could mean a fuel-limited fire that is producing little smoke or, as in this case, it could mean a ventilation-limited fire that is in the initial decay stage and is starved for air. In order to increase firefighter safety, consider treating every fire like a ventilation-limited fire until proven otherwise.




Figure 4.21: Changing smoke conditions




Figure 4.22: Pressure and Oxygen Concentrations that Impact Smoke Showing

4.9. Impact of Shut Door on Victim Tenability and Firefighter Tenability

The most likely place to find a victim that can be rescued is behind a closed door. In every experiment, a victim in the closed bedroom would be tenable and able to function through the length of the experiment and well after fire department arrival. In the open bedroom, this would be a very different story.

When it comes to rescuing occupants, the fire service makes risk-based decisions on the tenability of victims. They assume personal risk if it may save someone in the house. Each of the experiments included one closed bedroom next to an open bedroom. This allowed for the comparison of tenability of two side-by-side bedrooms; one with an open door and another with the door closed. The assumption here is that the occupant already had a closed door, or they closed it when the fire was discovered.

Table 4.1 and Table 4.2 show the times to carbon monoxide and temperature untenability for occupants in the open and closed bedrooms at 3 ft. above the floor in both houses. In every experiment, a victim in the closed bedroom would have been tenable and able to function throughout the experiment and well after fire department arrival. In the open bedroom, there would be a very different story; most victims would be unconscious, if not deceased, prior to fire department arrival or as a result of fire ventilation actions.

Table 4.1: One-Story CO and Temperature Tenability at 3 ft. above the Floor in the Open and Closed Bedrooms

Experiment	Open Bedroom CO (mm:ss)	Closed Bedroom CO (mm:ss)	Open Bedroom Temp (mm:ss)	Closed Bedroom Temp (mm:ss)	Firefighter Arrival
1	05:54	N/A	07:00	N/A	8:00
3	05:53	N/A	07:17	N/A	8:00
5	Equipment Malfunction	N/A	05:57	N/A	8:00
7	07:04	N/A	06:18	N/A	8:00
9	06:06	N/A	16:16	N/A	6:00
11	06:11	N/A	07:29	N/A	6:00
13	11:54	N/A	N/A	N/A	10:00
15	05:51	19:33	04:58	N/A	6:00
17	29:04	N/A	29:13	N/A	24:00

Table 4.2: Two-Story CO and Temperature Tenability at 3 ft. above the Floor in the Open and Closed Bedrooms

Experiment	Open Bedroom CO (mm:ss)	Closed Bedroom CO (mm:ss)	Open Bedroom Temp (mm:ss)	Closed Bedroom Temp (mm:ss)	Firefighter Arrival
2	11:46	N/A	07:34	N/A	10:00
4	13:22	N/A	09:04	N/A	10:00
6	12:42	N/A	08:23	N/A	10:00
8	12:35	N/A	08:34	N/A	10:00
12	10:50	N/A	07:31	N/A	8:00
16	18:54	32:14	27:05	N/A	27:00

NOTE: Experiments 10 and 14 were removed because the open bedroom was the fire room.

4.10. Softening the Target

Applying water to the fire as quickly as possible, regardless of where it is from, can make conditions in the entire structure better. Even a small amount of water has a positive impact on conditions within the house, increasing the potential for victim survivability and firefighter safety.

During these experiments, water was applied into a door or window with fire coming from it or with access to the fire from the exterior for approximately 15 seconds. This included stopping water flow for 60 seconds while conditions were monitored. This small amount of water had a positive impact on conditions within the houses, increasing the potential for victim survivability and firefighter safety. If a firefighter crew moved in and continued to suppress the fire, conditions would have improved that much faster.



During size-up, firefighter crews should assess the fastest and safest way to apply water to the fire. This may include applying water through a window, through a door, from the exterior, or from the interior. Using the ranch house as an example, the first line can be positioned in a variety of places based on the location of the fire, what is determined from the size-up, staffing, and many other considerations. If getting water on the fire is a top priority, then the discussion becomes narrowed. Assuming the hoseline approaches from side A or the bottom of each figure,


then this first example with fire showing from the front door would have water applied through the front door. While this is not the traditional approach of fighting the fire from the unburned to the burned, it will make conditions better faster for victims and firefighters alike.

Example 2, with fire showing from the living room window, would have water applied through the front window before entering the doorway. While the front door and living room fire are attached in this floor plan, which is most likely not known upon arrival. The front door may not necessarily directly access this room. There could be an entranceway that would require the crew to make it down a hallway to get to the fire, placing the crew in the flow path once they open the door.

Example 3 has fire showing from a bedroom on side A. Applying water through the bedroom window would occur more quickly than navigating the interior of the home, regardless of interior layout or conditions.

Example 4 has smoke showing from the front door and fire showing from a kitchen window on side C. If it can be done quickly, it may be more efficient to apply water from the front door or interior than to stretch a hoseline to the back of the house. If the fire cannot be seen through the open front door and the path to the fire is unknown, then the better choice may be to stretch to the back and put water on the fire through the window, where it can be seen, to reach the seat of the fire.





Experiment 14 in the 2-story house is a good example of softening the target in a situation that is not commonly done in the fire service. Here, fire is showing from the second floor of Side A. (Figure 4.27 and Figure 4.28). The hoseline is typically charged in the front of the house prior to entry, but water is usually not flowed onto the fire prior to entry. However, even if the interior path to the fire is known, flowing water directly onto the fire is faster from the outside than it is from the inside. The visible flames were extinguished in less than 5 seconds; steam did not reduce smoke layer height; and by 15 seconds after water application, the smoke was beginning to lift and conditions were improved.

A common argument against flowing water onto the fire prior to entry is the belief that conditions beyond the fire would be made worse. Data from this experiment showed otherwise. Temperatures were measured in the hallway just outside the room and in the other bedrooms on the second floor, (Figure 4.29). As shown in Figure 4.29, 25 gallons of water directed off of the ceiling of the fire room decreased fire room temperatures from 1792 °F to 632 °F in 10 seconds and the hallway temperature decreased from 273 °F to 104 °F in 10 seconds. Figure 4.30 through Figure 4.33 show the interior conditions as water was applied from the outside.



Figure 4.27: Conditions prior to arrival



Figure 4.28: Water being applied from outside the house




Figure 4.29: Experiment 14, Second Floor, Straight Stream



Figure 4.30. Just before water application



Figure 4.31: Five seconds into water application, visible flame out



Figure 4.32: At end of water application, steam moving to roof vent



Figure 4.33: Fifteen seconds after water, smoke layer lifting

4.11. You Can't Push Fire

You cannot push fire with water. The previous UL ventilation study included the concept of pushing fire in the data analysis. That study generated a lot of discussion, and stories surfaced from well-respected fire service members who had experienced the phenomenon of pushing fire, or had perceived that it had happened. The specific fires recalled by the firefighters were discussed in detail. In many of these situations, the firefighters were in the structure and in the flow path opposite the hoseline. In most cases, the event described occurred while fire attack crews were advancing on the inside, and not while applying water from the outside into a fully developed fire. All of the experiments in this study were designed to examine the operations and the impact of the initial arriving fire service units. It is not suggested that firefighters position themselves in a flow path opposite the hoseline. However, there are times when this may happen so the experience of these firefighters should not be discounted. Also, the experiments did not simulate water being applied from inside the structure by an advancing hoseline. It is understood that this happens on most fires.

During the discussions, four events were identified that could have been witnessed, and have had the appearance of pushing fire:

1) A flow path is changed with ventilation and not water application. When the firefighters are opposite the hoseline, in many cases they entered from a different point than the hoseline and left the door or window open behind them. This flow path is entraining air low, where they are crawling, and hot gases are exiting over their heads. As the fire reacts to the added air, the burning moving over their heads increases and conditions could deteriorate quickly. If an attack crew is preparing to move in or is inside, the experience of the firefighters opposite the hoseline could be blamed on the hoseline. However, the fire was just responding to the air and the added flow path and not to water flow. Often this occurs in close timing of water application and occurs without coordination (Figure 4.34).




Figure 4.34: Heat experienced by search crew because of ventilation no water application

2) A flow path is changed with water. Opening a wide fog changes the flow path or plugs a flow path (Figure 4.35 and Figure 4.36); this can also be accomplished with a straight stream when whipped in a circular pattern (Figure 4.37 through Figure 4.39). This can disrupt the thermal layer and move steam ahead of the line, which is why firefighters do it. If a firefighter is downstream, they may get the impression of pushing fire or elevated heat, especially if they are in the cool inflow of another vent location.



Figure 4.35: Flow path before Water Application



Figure 4.36: Fog Stream Sealing Flow Path



Figure 4.37: Prior to Water




Figure 4.38: Smooth bore being Whipped in a circular pattern blocking flow path out of Fire room



Figure 4.39: Flow path out re-established after Stream was Shut Down

3) Turnout gear becomes saturated with energy and passes through to firefighter. It is important for firefighters to know how their gear protects them. Gear absorbs energy to keep it from

getting to the firefighter inside. After the gear has already absorbed what it can, any additional energy can pass through to the low temperature firefighter inside the encapsulation. In some cases, firefighters inside a structure have been absorbing energy for some time. When a hoseline is opened in close proximity to this saturation time, then it may be interpreted that the hoseline caused a rapid heat build-up when, in fact, it could be that their gear was saturated and heat began to pass through.



4) One room is extinguished, which allows air to entrain into another room, causing it to ignite or increase in burning. Certain types of buildings have a layout where rooms are attached in a linear fashion. These are commonly referred to as railroad or shot gun layouts. In these structures, it is possible for multiple rooms to be on fire. Once one room gets suppressed, the ventilation-limited room behind it now has access to oxygen to increase burning. Usually, the hoseline cools several of these rooms at the same time. There may be a case, however, where doorways are offset, and water does not make it to the second room.

Figure 4.40 shows a fire that started in the middle room of a railroad flat structure and spread to the right room because of the air supplied by the open doorway. The left room and the middle room have decreased in temperature due to the lack of oxygen making it back to these rooms. The right room has flashed over and fire is showing out of the doorway.

Figure 4.41 shows how conditions change after water is flowed into the right room. The water decreases the burning and allows air to be entrained into the ventilation-limited middle room, allowing it to flashover. This could be interpreted as the hoseline pushing the fire to the middle room. However, it is flow paths that explain the fire dynamics, and not the water flow that caused the middle room to flashover.




Figure 4.40: Rail Road Flat Fire before Water Application




Figure 4.41: Rail Road Flat Fire after Water Application

4.12. Big volume, apply water to what is burning

In larger volume spaces, such as the family room/great room in the 2-story house, it is important to put water on what is burning. In modern floor plans with high ceilings and great rooms, there is a very large volume. Water application in these structures is not the same as a legacy home with smaller rooms and eight foot ceilings. Much of the water applied to a flashover condition in a small room will knock down a burning surface and the gases will cool as the water is converted to steam. In modern floor plans, a stream of water can end up several rooms away from the room that has flashed over. In order to have the biggest impact, water should be directed onto burning objects if possible.

The same open floor plan that can allow water to flow beyond the fire room can also allow for suppression of a fire that is several rooms away. In open floor plan houses, the reach of a hose stream can be beneficial, whereas in an older, divided home, it may not be as useful. In the 2-story floor plan, water can be applied into any room from more than 20 ft. away with some open lines of sight longer than 35 ft. (Figure 4.42). This allows the fire to be knocked down from a safer distance, without needing to be in the room or right next to the room to begin suppression.

In addition, every bedroom on the second floor could have water flowed into it from the first floor before proceeding up the stairs.




Figure 4.42: 2-story open floor plan with hose stream reaches

In Experiment 16, two rooms (Kitchen and Family Room) were involved in fire when water was applied. As flames were venting from the family room window, water was intentionally directed toward the kitchen fire for 15 seconds. While this slightly cooled the kitchen area, the family room fire was still fully developed and maintaining high temperatures in the remainder of the house. Once the stream was directed into the family room, the temperatures in the whole house cooled significantly.

5. Summary of Findings:

There has been a steady change in the residential fire environment over the past several decades. These changes include larger homes, more open floor plans and volumes, and increased synthetic fuel loads. UL conducted a series of 17 full-scale residential structure fires to examine this change in fire behavior and the impact of firefighter ventilation and suppression tactics. This fire research project developed the experimental data that is needed to quantify the fire behavior

associated with these scenarios, and result in the immediate development of the necessary firefighting ventilation practices to reduce firefighter death and injury.

The fuel loads acquired for these experiments produced approximately 9 MW to 10 MW, which was enough energy to create the necessary ventilation-limited conditions in both houses. The bedrooms and living rooms were loaded to between 2 lb/ft² and 4 lb/ft² and the kitchens were loaded to between 4 lb/ft² and 5 lb/ft². These could be considered low compared to actual homes, which have more clutter. Despite this, ventilation-limited conditions were created, and additional loading would just allow the fire to burn longer. Additionally, the heat release rate and total heat released from the living room fuel load is within 10% of that of the fuel load used in the previous study on horizontal ventilation, such that the experiments can be compared for various horizontal and vertical ventilation scenarios. Doubling the volume of the fire room by raising the ceiling height while maintaining the same amount of ventilation does not significantly slow down the time to flashover due to the rapid increase in heat release rate that occurs prior to flashover. Each room fire experiment transitioned to flashover in 5:00 to 5:30 after ignition.

Limiting the air supply to the fire was found to be an important consideration for the ventilation-limited fires in this series of experiments. The experiments where the door was opened to allow access and then closed the width of a hoseline slowed the growth of the fire, which maintained lower interior temperatures and better gas concentrations than if the door were opened completely. This allows for fire department intervention while keeping the fire at a lower heat release rate, which makes it easier to extinguish.

There was not a ventilation hole size used (4 ft. by 4 ft. or 4 ft. by 8 ft.) in these experiments that slowed the growth of the fire. All vertical ventilation holes created flashover and fully developed fire conditions more quickly. Once water was applied to the fire, however, the larger the hole was, and the closer it was to the fire, allowed more products of combustion to exhaust out of the structure, causing temperatures to decrease and visibility to improve.

Ventilating over the fire is the best choice if your fire attack is coordinated. If a ventilation-limited fire receives air, it will increase in size. Additionally, the closer the source of the air to the seat of the fire, the quicker it will increase in size. If you ventilate in coordination with fire attack (the hose stream is removing more energy than is being created), it does not matter where you ventilate, but the closer to the seat of the fire, the more efficient the vent will be in removing heat and smoke, which will improve conditions for the remainder of the operations taking place on the fire ground. Ventilating remote from the fire can be effective under some circumstances. If the fire is in a room that is connected to the rest of the house by a doorway, ventilating the roof outside of that room could allow for smoke to be cleared from the rest of the house. However, as air is entrained to the room, the fire will increase in size, while visibility may improve in the flow path leading from the air inlet to the fire room. The reason the fire does not grow uncontrolled is because the doorway becomes the limiting factor in keeping the fire contained. Once fuel outside of that doorway ignites, such as a bedroom fire extending to living room furniture, the heat release rate can increase quickly and overcome the temporary benefit of the remote vertical ventilation hole. Vertical ventilation remote from the fire can provide a visibility benefit but the fire and temperatures in the area of the fire are increasing.

Flow paths and timing are very important to understanding fire dynamics and the impact of firefighter tactics on the fire ground. The closer the air is provided to the seat of the fire, the faster it can intensify. Several experiments showed that fire showing does not mean that the fire

is vented; it means it is venting and still remains ventilation-limited. In every experiment, the fire was burning outside of the window or roof ventilation hole because there is no air available inside to burn. It is not possible to make statements about the effectiveness of ventilation unless you include timing while understanding that the longer the fresh air has to travel, the slower the fire will react to it. However the larger the flow path to catch firefighters in between where the fire is receiving fresh air and where the fire is exhausting to the low pressure behind them the greater chance that a rapid change can result in a negative outcome.

The fire service's workplace has changed and one of several significant factors is home furnishings. As home furnishings have evolved over decades to be made of synthetic materials, the heat release rates generated by home furnishings have increased significantly. This change speeds up the stages of fire development, creating an increased potential for ventilation-limited fire conditions prior to fire department arrival. In these experiments, it took 5 minutes for the modern fuel to transition the one-story house to ventilation-limited conditions while the legacy fuel took approximately 18 minutes. Earlier ventilation-limited conditions make the ventilation tactics of the fire service of utmost importance. Most importantly, the time between ventilation and flashover are 2 minutes for the modern fire and over 8 minutes in the legacy fire. The legacy fire could be described as forgiving as it pertains to ventilation. Poorly timed ventilation or an uncoordinated attack can be made up for prior to flashover because there is 8 minutes to adapt. The time to recover in the modern fire was 2 minutes, or 25% of the legacy time.

Tenability was exceeded in the fire room of every experiment prior to fire department arrival except for the legacy experiment in the one-story house. Behind a closed door is the most likely place to find a victim that can be rescued. Every experiment included one closed bedroom next to an open bedroom. In every experiment, a victim in the closed bedroom was tenable and able to function throughout every experiment and well after fire department arrival. In the open bedroom, there would be a very different story. Most victims would be unconscious, if not deceased, prior to fire department arrival or as a result of fire ventilation actions. The average time to untenability in the open bedroom was 7:30 taking into account temperature and carbon monoxide concentrations, while the closed bedroom did not exceed either of these criteria until well after fire department intervention.

Water was applied to the fire from the exterior during every experiment, in some experiments through the doorway and some through the window. Water was flowed for approximately 15 seconds, delivering 25 gallons of water into the structures. Comparing temperatures just before water application to temperatures 60 seconds after flow was stopped resulted in an average of a 40% decrease in fire room temperatures and a 22% decrease in the temperatures of surrounding rooms. In almost all of the experiments, tenability was improved everywhere in both structures with the application of water into the structure, even in locations downstream of the fire in the flow path. The data demonstrated the potential benefits of softening the target prior to making entry into the structure; the inability to push fire, as fire was never close to being forced from one room to another with a hose stream; and the benefits of applying water to the seat of the fire in a large open volume.

The fire dynamics of home fires are complex and challenging for the fire service. Ventilation is paramount to understand for safe and effective execution of the mission of the fire service to protect life and property. Vertical ventilation is especially important because it requires being positioned above the fire and can have a fast impact on interior fire conditions. This research

study developed experimental fire data to demonstrate fire behavior resulting from varied ignition locations and ventilation opening locations in legacy residential structures compared to modern residential structures. This data will be disseminated to provide education and guidance to the fire service in proper use of ventilation as a firefighting tactic that will result in reduction of the risk of firefighter injury and death associated with improper use of ventilation and to better understand the relationship between ventilation and suppression operations.

6. Bibliography

- Fahy, F., LeBlanc, P., & Molis, J. (2007). *What's Changed in the Past 30 Years*. Quincy: NFPA.
- Gann, R. a. (2008). Combustion products and their effects on life safety. In *The Fire Protection Handbook*. Quincy, MA: NFPA.
- ISO 13571. (2012). *Life-threatening components of fire – Guidelines for the estimation of time to compromised tenability in fires*. ISO.
- Karter, M. (2012). *Fire Loss in the United States during 2011*. Quincy: NFPA.
- Kerber, S. (2010). *Impact of Ventilation on Fire Behavior in Legacy and Contemporary Residential Construction*. Northbrook: Underwriters Laboratories.
- Kerber, S. (2012). Analysis of Changing Residential Fire Dynamics and its Implications on Firefighter Operational Timeframes. *Fire Technology*, 865-891.
- Kerber, S. (2012). Analysis of One and Two-Story Single Family Home Fire Dynamics and the Impact of Firefighter Horizontal Ventilation. *Fire Technology*.
- Michael J. Karter, J., & Molis, J. L. (2010). *U.S. Firefighter Injuries - 2009*. Quincy: NFPA.
- National Fallen Firefighters Foundation. (2005). *National Fire Service Research Agenda Symposium*. Emmitsburg: NFFF.
- National Firefighter Near Miss Reporting System. (2009). *Lightweight construction Reports*. Washington D.C.: IAFC.
- NFPA. (2013). *NFPA 1981: Standard on Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*. Quincy, MA: National Fire Protection Association.
- NIOSH. (1998). *Commercial Structure Fire Claims the Life of One Fire Fighter—California*. Morgantown: NIOSH.
- NIOSH. (2005). *Career Fire Fighter Dies and Two Career Captains are Injured While Fighting Night Club Arson Fire - Texas*. Morgantown: NIOSH.
- NIOSH. (2008). *A Volunteer Mutual Aid Captain and Fire Fighter Die in a Remodeled*. Morgantown: NIOSH.
- NIOSH. (2008). *Volunteer Fire Fighter and Trapped Resident Die and a Volunteer Lieutenant is Injured following a Duplex Fire - Pennsylvania*. Morgantown: NIOSH.
- NIOSH. (2009). *Nine Career Fire Fighters Die in Rapid Fire Progression at Commercial Furniture Showroom – South Carolina*. Morgantown: NIOSH.
- NIOSH. (2010). *NIOSH Alert: Preventing Deaths and Injuries of Fire Fighters using Risk Management Principles at Structure Fires*. Morgantown: NIOSH.

UL FIREFIGHTER SAFETY RESEARCH INSTITUTE



UL's Firefighter Safety Research Institute is dedicated to increasing firefighter knowledge to reduce injuries and deaths in the fire service and in the communities they serve.

Working in partnership with the fire service, research departments and agencies, FSRI executes cutting-edge firefighter research and makes the results widely available to the global fire community. With a team of pioneering experts and access to UL's leading infrastructure, equipment and vast knowledge and insights, FSRI conducts and disseminates cutting-edge research and training programs that focus on the changing dynamics of residential, commercial and industrial fires, and the impact they have on the fire service tactics and strategies

Visit Us: ULfirefightersafety.com

Like Us: facebook.com/ULfirefightersafety

Follow Us: twitter.com/UL_FSRI

Email: fsri@ul.com